

GENERAL NOTES:

- 1. TYPE 1 ENCLOSURE, 24" x 20" x 7".
- 2. SHORT CIRCUIT CURRENT RATING: 5,000 AMPS RMS SYMMETRICAL.
- 3. THIS PRODUCT HAS EARNED THE UL LISTING MARK.

NOTES:

- 1. 460 VAC, 3Ø, 60 HZ SERVICE. USE COPPER WIRE, 75° C INSULATION. FIELD TO INSTALL DISCONNECTING MEANS AND FUSE/BREAKER PROTECTION.
- 2. 15-AMP, CLASS J, TIME-DELAY FUSES.
- 3. LLS CONTACT (1&2) IS FACTORY SUPPLIED. CONTACT OPENING STOPS PUMP. CONTACT IS ELECTRICALLY NORMALLY OPEN, CLOSED BY WATER ABOVE SWITCH LEVEL.
- 4. LLS CONTACT (3&4) IS FACTORY SUPPLIED. CONTACT CLOSURE CAUSES ALARM. CONTACT IS ELECTRICALLY NORMALLY CLOSED, OPENED BY WATER ABOVE SWITCH LEVEL.
- 5. PCS IS FIELD SUPPLIED. CONTACT CLOSURE STARTS PUMP.

= ALARM SILENCE DTS = DUPLEX TRANSFER SWITCH = FUSE

= GROUND

HOAS = HAND-OFF-AUTO SWITCH = HORSEPOWER

CONTROL RELAY = LINE

= LOW LEVEL LIGHT LLS = LOW LEVEL SWITCH

М = MOTOR MOTOR STARTER MS = OL = OVERLOAD

PCS = PUMP CONTROL SWITCH RUN LIGHT = = TRANSFORMER

INTERNAL CONDUCTOR

_EXTERNAL_CONDUCTOR_

- o ELECTRICAL CONNECTION
- CONNECTION

Revisions:			
_	-	-	L
_	_	-	EI ES INDUSTRIES, LLC
_	_	_	BUTNER, NORTH CAROLINA
_	_	_	
_	_	_	DESCRIPTION G5127BX-5D DUPLEX FEED-PAC
_	_	_	
_	_	_	S.O.#
_	_	_	JOB
_	_	_	
_	_	_	
_	_	_	CUSTOMER
		THE PROPERTY OF BFS INDUSTRIES, LLC,	Scale: NONE Date Drawing no Rev.
		TO CHANGE WITHOUT NOTICE. THE INFORMATION	Drawn 1000CD CC 0
INDICATED, AND IS NOT TO BE COPIED, TRANSMITTED OR USED IN ANY WAY DETRIMENTAL TO THE COMPANY.		IS NOT TO BE COPIED, TRANSMITTED OR	Apprud: J. Samborsky / 9990D - SC 0